



ISO 9001 : 2015 CERTIFIED COMPANY
Reg. No.: KDACQ201612045

World Class
SAFETY KING
The Complete Fire & Safety Solutions
(Registered Government Of India)

A-ONE FIRE SAFETY SERVICES

ALL TYPE FIRE FIGHTING AND P.P.ES, ROAD SAFETY PRODUCTS

85-86-87, Sardar Complex, Opp, Sardar Bridge, Adajan Road, SURAT -9 Phone.: +91-261-2780504 / 2785466, Mob. : +91 98251 48113

Email : mandeepa1@yahoo.com | a1firesafety@gmail.com | Website : www.aonefiresafety.com

To,
Genius Education Academy,
Saniya-Chalthan Road, At Mohini,
Choriyasi, Surat.

24-02-2022

Subject: Your NOC Extension to two years dated 04/03/2023

Respected sir / ma'am,

This reference is about your NOC renewal as per your reference, receipt no.161/30, 161-22 dated 27/01/2021 and your Fire NOC outward no. 1595

Please be informed that the NOC issued on 30/01/2021 for Genius Education Academy (Saniya-Chalthan Road, At Mohini, Choriyasi, and Surat) is now extended till 29/01/2023, as per the given guidelines of **Gujarat government** (As per the notification published on 21/01/2022) (with attached copy)

So we will provide paid maintenance of your system for next one year. Like Hydrant system maintenance, fire extinguisher refilling, etc.

FPCOR (Fire Protection Consultant on Record)

Lic. No.FES/FPCOR/2018-14.

A ONE FIRE SAFETY SERVICES

Office: 85, 86, 87, 98, 99, 100,
SARDAR COMPLEX,
OPP. GUJARAT GAS CIRCLE,
ADAJAN ROAD,
SURAT/9,
GUJARAT



Principal
PRINCIPAL

GENIUS EDUCATIONAL ACADEMY
Mohini, Surat. CBSE AFF. NO. 120200

For Genius Educational Academy

Authorized Signature
Authorized Signature



"SAFETY, YOUR PREROGATIVE, OUR JOB"



**સુરત મહાનગરપાલિકા
ફાયર અને ઈમરજન્સી સર્વિસીસ**



—:: જાહેર જનતા જોગ જાહેર નોટીસ ::—

સરકારશ્રીનાં શહેરી વિકાસ અને શહેરી ગૃહ નિર્માણ વિભાગનાં પત્ર ક્રમાંક અગન-૧૦૨૦૨૧-૧૦૦-લ૧, તા. ૧૧/૦૧/૨૦૨૨નાં પત્ર મુજબ ગુજરાત અગ્નિ નિવારણ અને જીવન સુરક્ષા ઉપાય વિષયક નિયમો, ૨૦૧૪માં (સુધારો) નિયમો ૨૦૨૧ તા. ૨૨/૦૧/૨૦૨૧નાં જાહેરનામા **GH/V/9 OF 2021/AGN-102021-100-LI** થી બહાર પાડેલ નિયમ ૨૪ અને નિયમ ૨૫ સબસ્ટીટ્યુટ કરવામાં આવેલ જે મુજબ આ જાહેરનામા પછી એટલે કે તા. ૨૨/૦૧/૨૧ પછી સુરત મહાનગરપાલિકાનાં ફાયર વિભાગ દ્વારા રીન્યુ કરેલ ફાયર સેફ્ટી સર્ટીફિકેટ (એન.ઓ.સી.) ની વેલીડીટી ૨ (બે) વર્ષ ગણવાની રહેશે.

નં. પી.આર.ઓ./ /૨૦૨૧-૨૨
તા. /૦૧/૨૦૨૨

ચીફ ફાયર ઓફીસર
સુરત મહાનગરપાલિકા



Unifac
PRINCIPAL
GENIUS EDUCATIONAL ACADEMY
Molmi, Surat. GISE AFS NO. 430200

For Genius Educational Academy
Unifac
Authorised Signature



SURAT MUNICIPAL CORPORATION
FIRE & EMERGENCY SERVICES
HEAD QUATERS, MUGLISARA,
SURAT - 395003

Ph.: S.M.C. : 0261 - 2423750 TO 56, CONTROL : 2414195 -96, FAX : 2451935, 9724345553

To,
Genius Education Academy
Saniya-Chalthan Road, At-Mohini
Tal.Choriyasi, Dist-Surat.

Sub: - Inspection of Fire fighting system installed in Genius Education Academy Saniya-Chalthan Road, At-Mohini Tal.Choriyasi, Dist-Surat.

Ref: - Your Letter Dated:-28/12/2020

Sir,

With reference to the above, Fire Fighting System installed in **Genius Education Academy** Saniya-Chalthan Road, At-Mohini Tal.Choriyasi, Dist-Surat. was inspected by this dept on Dated - 15/01/2021.

During inspection of the said premises, following systems were found adequate and in working condition.

1	30 Mt. Hose Reel with Nozzle	YES
2	ABC Fire Extinguishers 6 kg Capacity	YES
3	CO2 Fire Extinguishers 2/4.5 Kg Capacity	YES
3	Main Fire pump with Auto System	YES
4	Fire Alarm System [MCP]	YES
5	Over Head Water Tank capacity 10,000 Liter	YES
6	Exit	YES

1. The Fire Fighting System to be Maintain perfect working condition all the time.
2. In case of Emergency, Fire Safety System must be operated by your trained person immediately
3. Parking shall not be permitted in courtyards and drive ways of fire appliances.
4. Courtyard shall be kept free from encumbrances & encroachments.
5. No structure of any type shall be permitted in courtyard of the building.
6. There shall not be any trees obstructing fire appliances reach in compulsory open spaces required as per CGDCR.
7. The access provided to the basement shall be kept unobstructed.
8. Repairing/servicing of cars, use of naked light shall not be permitted in the car parking areas.
9. Dwelling, use of naked light / flame, repairing / maintenance of vehicles shall be strictly prohibited in the parking area.
10. The driveways shall be property marked and maintained unobstructed, proper illuminated signage shall be provided for escape route.
11. Car parking shall be permitted in the designated area only.
12. Podium floor shall not be enclosed except for parapet walls.
13. Externally located staircases adequately ventilated to outside air.
14. Permanent vent at the top equal to 5 % of the cross sectional area of the staircase shall be provided.
15. No combustibles shall be kept or stored in staircase / passages.
16. The staircase should not be encroached by shoe-rack, decorative items, earthen pots etc.

PRINCIPAL

GENIUS EDUCATIONAL ACADEMY
Mohini, Surat. CRSP AFF NO 430200

Page | 1

For Genius Educational Academy
Authorised Signature




SURAT MUNICIPAL CORPORATION
FIRE & EMERGENCY SERVICES
HEAD QUARTERS, MUGLISARA,
SURAT - 395003

Ph.: S.M.C. : 0261 - 2423750 TO 56, CONTROL : 2414195 -96, FAX : 2451935, 9724345553

17. In case of failure normal electric supply, it shall automatically changeover to alternate supply. For apartment houses, this changeover of supply could be done through manually operated changeover switch. Alternatively, the lift shall be so wired that in case of power failure, it comes down at the ground level and comes to stand-still with door open.
18. The common corridor / lift lobby / emergency exit at each floor level shall be kept free from obstruction at all times.
19. The staircase and corridor lighting shall be on separate circuits and shall be independently connected so that they could be operated by one switch installation on the ground floor easily accessible to fire fighting staff at any time irrespective of the position of the individual control of the light points, if any.
20. Staircase and corridor lighting shall also be connected to alternate supply.
21. Emergency lights shall be provided in the staircase / corridors.
22. Electric shaft shall be sealed at each floor level with non-combustible material such as vermiculite concrete. No storage shall be permitted in electric cabin or shaft.
23. Electric wiring / cable shall be of non-toxic, non-flammable, low smoke hazard having copper core fire resistance for the entire building with provision of ELCB/MCB.
24. Electric meter room shall be adequately ventilated, accessible & shall not be under staircase, basement lift-lobby.
25. Electrical fittings / fixtures shall be installed in the premises as per Electricity Acts & Rules and should be tested from Govt. approved Electrical Inspector.
26. Master switches controlling essential services shall be clearly labeled & provide in the lobby for emergency operation.
27. Materials For Interior Decoration / Furnishing :
The use of materials which are combustible in nature and may spread toxic fumes/gases should not be used for interior decoration/furnishing, etc.
28. Fire drill / evacuation drill :
Fire drill and evacuation drill shall be conducted regularly in accordance with fire safety plan of building at least once in a three month in consultation with Mumbai fire brigade and log of the same shall be maintained.
29. Basement shall be used only permissible uses as per CGDCR-2017.
30. The entry /exit shall be kept free for any obstruction.
31. Astro turf etc. shall not be permitted in the courtyard and in the drive way.
32. This NOC is issued from fire risk point of view only.
33. Trained man power shall be available for the fire fighting and lift rescue in the building premises round the clock.
34. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning authority.
35. The certificate may not be treated in any case for regularization for unauthorized construction if any.
36. Self Declaration Certificate to be submitted by Owner & Fire Consultant to T.D.O. Department as per UDD Notification dated. 03.09.2019.
37. The fire department of SMC will not responsible for any loss of life and property due to fire / Emergency incident.

Principal
PRINCIPAL

GENIUS EDUCATIONAL ACADEMY
Mohni, Surat, CBSE AFF. NO. 430200



For Genius Educational Academy

Authorized Signature
Authorized Signature



SURAT MUNICIPAL CORPORATION
FIRE & EMERGENCY SERVICES
HEAD QUATERS, MUGLISARA,
SURAT - 395003


Ph.: S.M.C. : 0261 - 2423750 TO 56, CONTROL : 2414195 -96, FAX : 2451935, 9724345553

38. Our Fire Certificate is limited to Fire Fighting System available in your premises only.
39. Any other instructions given by fire dept. From time to time about fire safety of the premises to be Followed.
40. The administrative charge of Rs.500 x 2 = 1000/- has been recovered vide receipt No.161/30,161-22, Dated-27/01/2021.
41. The duration of the inspection report is valid up to One Year from the Date of Issue.

(I/C Dy.Chief Fire Officer)

FES/NOC/OUTWARD. 1595
DT.30-01-2021


for I/C CHIEF FIRE OFFICER
Surat Municipal Corporation



GENIUS EDUCATION ACADEMY
SANIYA-CHALTHAN ROAD, AT-MOHINI
TAL.CHORIYASI, DIST.SURAT

FES/NOC/OUTWARD NO:- 30-01-2021 / 1595

LICENCE NO:- FES/FPCR/2018-14

A-ONE FIRE SAFETY SERVICES




PRINCIPAL

GENIUS EDUCATIONAL ACADEMY
Surat, GSE AFF. NO. 430200

For Genius Educational Academy


Authorised Signature