

PRIMARY HEALTH CENTRE

MOHNI VILLAGE, BLOCK: CHORYASI, DIST: SURAT, GUJARAT-394305


Ref. No: 488

Date: 26/2/2022

HEALTH & SANITATION CERTIFICATE

I hereby declare that I have visited Genius Educational Academy, Mohni Village, Block: Choriyasi, Dist: Surat, CBSE affiliation no: 430200. I find the school campus and the surrounding very conducive for the children and the staff. Each of the several classes is sufficient for the maximum number of pupils. The classrooms are spacious, properly ventilated and lighted. The building and surrounding are kept neat and clean. The latrines and urinals are provided adequately and maintained well. There is sufficient amount of drinking water facility available. In all respect the sanitation is good.

So, I certify that the sanitary conditions of the said school are satisfactory.




Medical Officer
PHC Mohni
Medical Officer
PHC: Mohni
Ta. Choriyasi, Dist. Surat

To,
The Genius Educational Academy
Mohni Village, Saniya-Chalthan Road,
Dist: Surat- 394305, Gujarat


PRINCIPAL

GENIUS EDUCATIONAL ACADEMY
Mohni, Surat. CBSE AFF. NO. 430200

For Genius Educational Academy

Authorised Signature

 <p>GWSSB LABORATORIES</p>	<p>SCIENTIFIC OFFICER DISTRICT LABORATORY, 2ND FLOOR, 'JALBHAVAN', ADAJAN O/H WATER TANK COMPOUND, ADAJAN ROAD, SURAT-395009. PHONE / FAX : (0261)- 2782145.</p>	 <p>E mail : distlabsurat@gmail.com</p>	<p>વૈજ્ઞાનિક અધિકારીશ્રી, જિલ્લા પ્રયોગશાળા, ગુ.પા.પુ.અને ગ.વ્ય.બોર્ડ, 'જલભવન' બીજી માળ, અડાજણ ઊંચી પાણીની ટાંકી કમ્પાઉન્ડ, અડાજણ રોડ, સુરત-૩૯૫૦૦૯. ફોન/ફેક્સ નં : (૦૨૬૧)-૨૭૮૨૧૪૫.</p>	 <p>TO-7428</p>
--	---	--	--	--

Test Report

Name & Address of Customer:-

Shree Krushnalal Bhikhabhai Parekh
Charitable Trust Managed
Genius Educational Academy
Tal.- Choryasi
Dist-Surat.

Customer Reference No. : 23/OFFICE/57/2022.Dtd.25/02/2022

Sample Submitted by : Sender
Date of Sample Receipt : 25/02/22
Analysis Starting Date : 25/02/22
Analysis completion Date : 25/02/22
ULR No : TC742822000000398F
Discipline : Chemical Testing, Group: Water

Test Report No :	1062/2021-'22	Date of Issue :	25/02/22
Sample ID :	SCW-1062/02-'22	Mode of Sample :	Satisfactory
Main Source :	Ground Water	Source :	Tube Well
Location :	of Genius Educational Academy		
Village :	Mohani	Habitation :	Mohani
Taluka :	Choryasi	District :	Surat
Latitude :	----	Longitude :	----

Kindly find herewith the Analytical Results.

Sample Type : Drinking Water

Sr. No.	Parameter	Unit	IS-10500:2012 (2nd Revision)		Reference Method :	Analytical Value
			Requirement (Acceptable Limit) Max.	Permissible Limit in the Absence of Alternate Source Max.		
1	Colour	Hazen	5	15	APHA (23 rd Ed 2017), Method: 2120 G	<1.0
2	Turbidity	NTU	1	5	APHA (23 rd Ed 2017), Method: 2130 B	0.62
3	pH at 25°C	-	6.5 to 8.5	No relaxation	APHA (23 rd Ed 2017) Method: 4500 H ⁺ B	7.65
4	Conductivity at 25°C	µS/cm ₂	-	-	APHA (23 rd Ed 2017) Method: 2510 B	2540
5	Total Dissolved Solids	mg/l	500	2000	APHA (23 rd Ed 2017) Method: 2540 C	1358.0
6	Total Hardness(as CaCO ₃)	mg/l	200	600	APHA (23 rd Ed 2017) Method: 2340 C	339
7	Calcium (as Ca ²⁺)	mg/l	75	200	APHA (23 rd Ed 2017) Method: 3500 Ca ²⁺ B	49
8	Magnessium (as Mg ²⁺)	mg/l	30	100	APHA (23 rd Ed 2017) Method: 3500-Mg ²⁺ B	52
9	Chloride (as Cl ⁻)	mg/l	250	1000	APHA (23 rd Ed 2017) Method: 4500-Cl ⁻ B	324
10	Sulphate (as SO ₄ ²⁻)	mg/l	200	400	APHA (23 rd Ed 2017) Method: 4500-SO ₄ ²⁻ E	162
11	Nitrate (as NO ₃ ⁻)	mg/l	45	No relaxation	APHA (23 rd Ed 2017) Method: 4500-NO ₃ ⁻ B	31.72
12	Fluoride (as F ⁻)	mg/l	1	1.5	APHA (23 rd Ed 2017) Method: 4500-F ⁻ C	1.03
13	Total Alkalinity (as CaCO ₃)	mg/l	200	600	APHA (23 rd Ed 2017) Method: 2320 B	596


This Report is issued under the following terms & Condition :

1. This report is referring only to the tested sample and for applicable parameter.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part, and can't be used be as evidence in court of law.

Checked By :

(Chirag D. Rod)
Dy. Technical Manager

District Laboratory
Guj. Water Supply & Sew. Board
"JAL BHAVAN" 2nd Floor,
Adajan O/H Water Tank Compound,
Adajan Road, SURAT-395009. Guj.

Issued By:

(MEETA B. LAD)
Technical Manager
District Laboratory
GWSSB, Surat.

Dy.TMg /Chemist

Name & Designation of
Authorized Signatory

O.W.No. DLS/ 72 /of 2022, Dt. 25/02/2022.

End of the Test Report


PRINCIPAL
GENIUS EDUCATIONAL ACADEMY
Mohani, Surat. CBSE AFE NO. 430200

For Genius Educational Academy

Authorised Signatory



DISTRICT LABORATORY
Gujarat Water Supply Sewerage Board
SURAT



REPORT ON BACTERIOLOGICAL EXAMINATION OF WATER

Name & Address

Shree Krushnalal Bhikhabhai Parekh

Charitable Trust Managed

Genius Educational Academy
Surat

Sender's Ref. No. :

Ref No:-GEA/2022-
23/OFFICE/57/2022

Ref. Date. : 25/02/2022

Date & Time of Commencing Examination : 25/02/2022

Sample collected by : Sender

BW No.	SBW-1419
Date of Collection	25/02/22
Date of Arrival at Lab.	25/02/22
Source of Water Sample	Tube Well, of Genius Educational Academy
Village	Mohani
Habitation	Mohani
Taluka	Choryasi
District	Surat
APHA, AWWA, 9221-D Presence - Absence Coliform Test, @ 37° C	---
APHA, AWWA, 9221-F Presence - Absence E-Coli Test, @ 37° C	----
MPN of coliform per 100 ml of sample at 37° C	< 2
MPN of Faecal coliform per 100 ml of sample at 44° C	< 2
Free Chlorine (PPM)	NIL
OPINION FOR POTABILITY :	FIT

Important Note:-

1) '>=' Indicates greater than or equal to, 2) '<' Indicates less than, 3)'P' Indicates Presence, 4)'A' Indicates Absence

NOTE - Table - 6 Bacteriological Quality of Drinking Water (BIS:10500:2012) - Second Revision.

① All Water Intended for Drinking -

(a) E.coli or Thermotolerant coliform bacteria shall not be detectable in any 100ml sample.

② Treated Water Entering the Distribution system & Treated Water in the Distribution system -

(a) E.coli or Thermotolerant coliform bacteria shall not be detectable in any 100ml sample.

(b) Total coliform bacteria shall not be detectable in any 100ml sample.

③ 0.2ppm Free Residual Chlorine at consumer end is recommended.

1) Test Report is issued for assessing Bacteriological Fitness as per the BIS 10500:2012 for the given Drinking Water Sample only.

2) This Report should not be taken as a basis to getting license from any Government authority.

3) After Collection of Bact. Sample, it must be preserved at 4°C and submitted to laboratory within 24hrs.

District Laboratory
Guj. Water Supply & Sew. Board
"JAL BRAVAN" 2nd Floor,
Adajan O/H Water Tank Compound,
Adajan Road, SURAT-395009, Guj.

LABORATORY
INCHARGE

Outward No.: DL SRT/76/1 of 2022, Dt. 28/02/2022

DISTRICT LABORATORY, 2ND FLOOR, JALBHAVAN, ADAJAN O/H WATER TANK COMPOUND, ADAJAN ROAD, SURAT-395009.

PRINCIPAL
GENIUS EDUCATIONAL ACADEMY
Mohani, Surat, CBSE Aff. NO. 430200

Authorised Signatory